



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
6, Diamond Harbour Road, Silpara, Kol-700008

Memo No.:FSR/0125186231200436

Date : 03-05-2024

From :
Divisional Fire Officer
Fire Prevention Wing ,
West Bengal Fire & Emergency Services

To :
St John High School Co Ed
Usthi Road, Sirakol, Piyajunge More, P.S.-Usthi, Dist.-South 24 Parganas, Pin-743513

Sub : Fire Safety Certificate for the occupancy of an existing G+II storied under group educational building in the name & Style of St Jhon High School (Co Ed) at the premises no - R.S Dag No 2013 2007, Khatian No-788, J.L.No- 04, Usthi Road, Sirakol, Piyajunge More, Under Mouza Sirakol, P.S- Usthi, Dist- South 24 Parganas, Pin- 743513.

This is in reference to your AIN 211892406300000138 dated 29-Mar-2024 regarding Fire Safety Certificate for the occupancy of an existing G+II storied under group educational building in the name & Style of St Jhon High School (Co Ed) at the premises no - R.S Dag No 2013 2007, Khatian No-788, J.L.No- 04, Usthi Road, Sirakol, Piyajunge More, Under Mouza Sirakol, P.S- Usthi, Dist- South 24 Parganas, Pin- 743513..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

1. All the fire prevention and fire safety measures shall be maintained in good repair and efficient condition at all times in accordance with the provision of Section 11 C of West Bengal Fire service Act 1950 with up to date amendment.
2. Construction of alternative staircase shall be completed within 30 days from the received of this certificate.
3. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300000138

4. Good housekeeping shall be maintained.
5. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
6. Electrical wiring of the all building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling & ducts. Electrical safety Audit to be conducted positively by 31st March every year.
The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the Building.
7. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
8. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
10. Periodical flashing of water in the Hydrants, Pipe line shall be made to maintain the efficiency working performance of above mention system.
11. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
12. This certificate valid for 03 years. A Renewal Certificate shall have to be obtained every three years from the date of issuance of this certificate from the Divisional Fire Officer South 24 Parganas Division, West Bengal Fire & Emergency Services for performance of all the life & Fire Safety arrangements and installations of the building.

Valid Upto : 03-May-2027

Memo No.:FSR/0125186231200436



Signature valid

Digitally Signed,
Name: SHYAM CHANDRA MONDAL
Date: 03-May-2024 16:45:02
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300000138